



# 2023 Residential Energy Improvement Program

Measure	Existing Condition	Minimum Requirement	Customer Incentives		
Duct Sealing	$\leq 40\%$ Total fan flow & $> 80$ CFM <sub>25</sub>	$> 10\%$ Reduction	Single Family: \$1.25/CFM Reduction Multifamily: \$1.75/CFM Reduction		
Duct Insulation	Failed insulation or no insulation installed (metal ducts only)	$\geq R-5.6$	\$0.50/Linear ft. of insulated duct		
Air Infiltration	$\leq 1.25$ Air changes/hr & $>$ building air tightness limit	$\geq 10\%$ Reduction at CFM <sub>50</sub>	Single Family: \$0.12/CFM Reduction Multifamily \$0.20/CFM Reduction		
Attic Knee Wall Insulation	No insulation installed	R-19	\$0.15/sq. ft. of knee wall insulated		
Wall Insulation	No insulation installed (vinyl siding)	R-13	\$0.15/sq. ft.		
Ceiling Insulation	Base R-value $0 < 8$	R-38	\$0.25/sq. ft.		
	Base R-value $\geq 8-22$	R-38	\$0.12/sq. ft.		
CoolSaver HVAC Tune-Up	Central Air Conditioner, Heat Pump or Package unit (Excludes Geothermal)	CoolSaver Authorized Contractor, system $> 1$ year old	1.5–2.5 Ton \$150 3.0–5.0 Ton \$200		
Hybrid Water Heaters (heat pump)	Electric Water Heater	ENERGY STAR® Certified	\$500		
ENERGY STAR Windows	Clear Glass Windows (without Low-E)	ENERGY STAR windows for climate zone installed	\$30/Window \$40/Half-lite door \$80/Sliding glass door		
ENERGY STAR Smart Thermostats	Manual or Programmable Thermostat	ENERGY STAR Certified	\$75		
AC Installation	$\leq 13$ SEER	16 SEER AC	<u>SEER</u>	<u>SEER2</u>	<u>\$/Ton</u>
			16.00-17.99	15.2 - 17.09	\$75
			18.00 – 20.99	17.1 - 19.94	\$150
			$\geq 21.00$	$\geq 19.95$	\$200
Heat Pump Installation	$\leq 13$ SEER $\leq 7.7$ HSPF	16 SEER/8.5 HSPF/3.6 COP Heat Pump, Mini-Split or Geothermal System	<u>SEER</u>	<u>SEER2</u>	<u>\$/Ton</u>
			16.00-17.99	15.2 - 17.09	\$250
			18.00 – 20.99	17.1 - 19.94	\$400
			$\geq 21.00$	$\geq 19.95$	\$500